



Compress Test Report




AYRIKO Company

www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder

Information engine

Code :	1	Unit Type :	cat 3520c	Date Test :	98-6-29
Name :	setare	Unit Make :	cat	Quantity Cylinder	20
Unit Particle :	b1-b19	Unit Model :	3520c	RPM Engine :	1500
Location :	babolsar	Capacity Engine	2000KW	RPM Start Engine	1500
Temp Environment	38	Temperature Oi	35	Density Ratio :	11
Address : babol					






Compress Test Report

AYRIKO Company


www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder




Peak Table Pressure

11.51	13.30
12.95	13.23
13.01	13.22
13.19	13.15
13.29	13.25
13.22	13.29
13.16	13.22
13.18	13.18
13.27	13.19




Peak Table Pressure

12.77	13.19
12.81	13.04
13.02	12.94
13.10	13.11
13.14	13.15
13.13	13.10
13.00	13.05
13.06	12.98
13.07	13.12



Peak Table Pressure

12.86	13.12
12.98	13.17
13.07	13.18
13.15	13.21
13.21	13.13
13.16	13.10
13.11	13.19
13.21	13.22
13.14	13.22



Peak Table Pressure

12.95	13.13
13.01	13.13
13.04	13.19
13.21	13.29
13.25	13.26
13.08	13.12
13.19	13.16
13.20	13.27
13.26	13.29




Compress Test Report

AYRIKO Company


www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder




Peak Table Pressure

3.65	13.43
13.13	13.39
13.08	13.38
13.22	13.39
13.33	13.33
13.34	13.40
13.36	13.38
13.30	13.36
13.45	13.37



Peak Table Pressure

13.04	13.38
13.04	13.24
13.11	13.24
13.19	13.36
13.23	13.39
13.28	13.31
13.26	13.21
13.37	13.28
13.26	13.36



Peak Table Pressure

13.60	13.34
12.97	13.23
13.02	13.17
13.12	13.23
13.19	13.31
13.14	13.27
13.07	13.27
13.22	13.13
13.29	13.24