



Compress Test Report

AYRIKO Company


www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder

Information engine


Code :	3	Unit Type :	mwm	Date Test :	98-3-5
Name :	mr shahhoseini	Unit Make :	deutz	Quantity Cylinder	12
Unit Particle :		Unit Model :	TBG620V12K	RPM Engine :	1500
Location :		Capacity Engine	1000KW	RPM Start Engine	1500
Temp Environment		Temperature Oi		Density Ratio :	

Address :




Peak Table Pressure

13.75	13.31
13.69	13.12
13.33	13.29
13.36	13.10
13.11	13.00
13.13	13.04
13.12	13.29
13.31	13.37
13.20	13.11



Peak Table Pressure

13.20	13.08
13.42	13.09
13.15	12.78
13.12	12.99
12.84	13.00
12.91	12.98
12.85	13.09
13.03	12.97
13.07	12.97



Peak Table Pressure

3.54	13.19
13.71	13.16
13.62	13.38
13.40	13.10
13.27	13.28
13.11	13.29
13.12	13.28
13.22	13.18
13.37	13.37




Compress Test Report

AYRIKO Company

www.AYRIKO.ir
www.AYRIKO.com

The first manufacturer of digital pressure cylinder




Peak Table Pressure

13.47	13.09
13.40	13.04
13.33	12.90
13.15	12.89
12.85	12.98
12.86	12.96
12.84	12.94
13.02	12.96
13.02	13.10



Peak Table Pressure

13.39	12.90
13.32	12.96
13.17	13.00
12.99	13.02
12.81	12.97
12.81	13.02
12.88	13.10
13.05	12.89
12.83	13.08



Peak Table Pressure

13.88	13.22
13.77	13.25
13.61	13.23
13.28	13.17
13.17	13.03
13.13	12.99
13.07	13.16
13.20	13.28
13.33	13.24