



# Compress Test Report

**AYRIKO Company**


www.AYRIKO.ir  
www.AYRIKO.com

The first manufacturer of digital pressure cylinder

## Information engine


Code :	1	Unit Type :	mwm	Date Test :	98-12-6-2
Name :	yegane	Unit Make :	mwm	Quantity Cylinder	12
Unit Particle :	a1-a6	Unit Model :	2020	RPM Engine :	1500
Location :	shahriar	Capacity Engine	1200KW	RPM Start Engine	180
Temp Environment	20	Temperature Oi	20	Density Ratio :	11

Address :




Peak Table Pressure

21.49	22.29
22.00	22.35
21.96	22.51
22.26	22.15
21.96	22.38
22.35	22.53
22.14	22.28
22.38	
22.36	



Peak Table Pressure

18.87	20.34
19.65	20.21
19.95	20.33
19.99	20.48
20.26	20.35
19.99	20.18
20.33	20.34
20.29	13.87
20.19	



Peak Table Pressure

2.76	21.18
20.38	21.25
20.81	21.23
20.87	20.89
20.55	21.33
21.02	21.43
20.90	21.42
21.26	19.82
21.17	




# Compress Test Report

**AYRIKO Company**

[www.AYRIKO.ir](http://www.AYRIKO.ir)


[www.AYRIKO.com](http://www.AYRIKO.com)

The first manufacturer of digital pressure cylinder




Peak Table Pressure

16.83	18.20
17.85	18.40
18.21	18.28
17.87	18.77
18.28	18.60
17.94	18.61
18.44	18.41
18.27	
18.47	



Peak Table Pressure

20.89	21.29
20.66	20.96
20.91	21.24
20.95	21.25
21.06	21.26
21.16	20.99
21.04	20.58
21.29	
20.83	



Peak Table Pressure

21.43	21.76
21.16	21.20
21.16	21.35
21.47	21.52
21.44	21.28
21.54	21.54
21.35	21.70
21.60	18.90
21.18	